



Requisition Number: PR8504430

Requisition Title: AUTOMATIC VOLTAGE REGULATOR FOR RR PUMP ROOM

Purchase Request: PR8504430

Request Type: Requisition

Requesting Office: AMERICAN EMBASSY NAIROBI

Issued on Tue, 30 Jul, 2019

Created on Tue, 30 Jul, 2019 by Reardon R. Muka

Vendor:

NOVENDOR

UNITED STATES

Ship To:

Department of State

U.N. AVENUE GIGIRI; PO BOX 606,00621

ATTN: FM-RESIDENTIAL - 1901.0

NAIROBI

KENYA

Item	Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount
1	AUTOMATIC VOLTAGE REGULATOR (AVR) WITH THE ... AUTOMATIC VOLTAGE REGULATOR (AVR) WITH THE BELOW SPECIFICATIONS: Rating: 250KVA, 415/240V, 50Hz, Indoor Type, Manufacturer: Omniverter, Emerson's Avtron or approved equal Minimum AVR details and supply options are: 1. Output: 415Y/240V, 50Hz. OUTPUT VOLTAGE: Pre-set to 240 V Ph-N (415V, L-L AC RMS \pm 0.5%. 3-Phase 4 Wire Star - User adjustable on site. 2. An input voltage range of +20%/-20%. Output voltage of +/- 0.5% or smaller for 3-Phase 4-wire systems each phase must be sensed and corrected independently. 3. The correction of voltage shall be 0.5 seconds or less. 4. It shall be customer adjustable for output voltage set-point changes of 5 volts or less. 5. SURGE PROTECTION. Class I shall be installed in the lineside and Class II on load side of the AVR. SPD/TVSS shall be Ortea		each	1	Thu, 29 Aug, 2019	\$0.00 USD	\$0.00 USD

Bill To:

Department of State

U.N. AVENUE GIGIRI; PO BOX 606,00621

ATTN: US EMBASSY FMC - 1901.0

NAIROBI

KENYA

Funding:

Type	Percentage	Amount(Local Currency)	Amount(USD)	Details
Commodity Accounting Line	100%	\$0.00 USD	\$0.00 USD	

Total \$0.00 USD