



EMBASSY OF THE
UNITED STATES OF AMERICA
P.O. BOX 606 - 00621, VILLAGE MARKET
NAIROBI, KENYA

February 9, 2021

Dear Prospective Vendor,

SUBJECT: REQUEST FOR QUOTATION NUMBER PR9683087 – RELOCATION OF 500KVA GENERATOR AND INSTALLATION

The Embassy of the United States of America, Nairobi, invites you to submit a quotation for relocation of 500KVA Generator and Installation as per attached scope of work.

The U.S. Government intends to award a contract to a responsible company submitting an acceptable quotation at a reasonable price. The RFQ does not commit the American Embassy to make any award. The Embassy may cancel this RFQ or any part of it. Your proposal must be submitted in two separate email attachments addressed to: To the Contracting Officer, American Embassy, through NairobiGSO-bids@state.gov With a copy to otienoBP@state.gov; **on or before February 24th, 2021 at 09:00AM**. The subject heading should be as follows:

1. **RFQ. PR9683087 FINANCIAL PROPOSAL:** This entails the price quotation indicating unit and total prices before VAT
2. **RFQ. PR9683087 TECHNICAL PROPOSAL** (*Must not have your Letter Head or Company Stamp/Seal i.e. it should be on plain paper*). Your quotation reference number is required on this which matches the price proposal number)


Please note that **Mandatory Site visits** has been scheduled as follows: -

- Tuesday 16th February 2021 starting 11:00am.**
- Meeting Point:** US Embassy Main Gate.

Send names and ID number of one representative per company for the site visit by 9AM Friday 12th February 2021.

The U.S. Government intends to award a purchase order to the responsible vendor submitting a technically acceptable quote with the lowest price, based on initial quotations without holding discussions, although we may hold discussions with companies in the competitive range if there is a need to do so. Prior to contract award, the successful offeror(s) will be required to have a DUNS number and be registered in SAM/COR through the following sites: DUNS – www.dnb.com and SAM/CCR www.sam.gov. Direct any questions regarding this solicitation to the **Contracting Officer, Nairobi** NairobiGSO-bids@state.gov and otienoBP@state.gov during regular business hours

Sincerely,
Aisha O'Neal


Contracting Officer



Requisition Number: PR9683087

Requisition Title: Relocation of 500KVA Generator and installation at 600

Purchase Request: PR9683087

Request Type: Requisition

Requesting Office: AMERICAN EMBASSY NAIROBI

Issued on Fri, 22 Jan, 2021

Created on Fri, 22 Jan, 2021 by Reardon R. Muka

Vendor:

NOVENDOR

UNITED STATES

Ship To:

Department of State
U.N. AVENUE GIGIRI; PO BOX 606,00621
ATTN: FM-RESIDENTIAL - 1901.0
NAIROBI
KENYA

Bill To:

Department of State
U.N. AVENUE GIGIRI; PO BOX 606,00621
ATTN: US EMBASSY FMC - 1901.0
NAIROBI
KENYA

Funding:

Type	Amount(Local Currency)	Amount(USD)	Details
Commodity Accounting Line	\$0.00 USD	\$0.00 USD	

Item	Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount
1	Pickup 500Kva Generator from Embassy compound...		each	1	Sun, 21 Feb, 2021	\$0.00 USD	\$0.00 USD
	Pickup 500Kva Generator from Embassy compound using crane and load to transportation truck						

Item	Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount
2	Transport 500Kva Generator from Embassy ...		each	1	Sun, 21 Feb, 2021	\$0.00 USD	\$0.00 USD
	Transport 500Kva Generator from Embassy compound to Rosslyn Ridge compound and offload to site						

Item	Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount
3	Construction of Generator plinth- as per ...		each	1	Sun, 21 Feb, 2021	\$0.00 USD	\$0.00 USD
	Construction of Generator plinth- as per attached document spec						

Item	Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount
------	-------------	-------------	------	-----	-----------------	------------	-----------------

4	Supply 35mm 4core flexible (Multiple strands)...		each	1	Sun, 21 Feb, 2021	\$0.00 USD	\$0.00 USD
Supply 35mm 4core flexible (Multiple strands) cable PVC Insulation (Polyvinyl Chloride) and mechanical protection rubber sheath. cable shall be 3 runs of 100mtres each.							

Item Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount	
5	supply and install 1000A 4pole manual ...		each	1	Sun, 21 Feb, 2021	\$0.00 USD	\$0.00 USD
supply and install 1000A 4pole manual change-over. Change over, change over HANDLE should be padlock lockable and wall mounted.							

Item Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount	
6	Provide adequate earthing on earthing mart ...		each	1	Sun, 21 Feb, 2021	\$0.00 USD	\$0.00 USD
Provide adequate earthing on earthing mart with earth inspection manhole cover for the Generator.							

Item Description	Part Number	Unit	Qty	Vendor Delivery	Unit Price	Extended Amount	
7	Provision for installation of 600KVA ...		each	1	Sun, 21 Feb, 2021	\$0.00 USD	\$0.00 USD
Provision for installation of 600KVA Generator, testing and commissioning.							

Total						\$0.00 USD
--------------	--	--	--	--	--	------------